

Saint Johnsville Police Department-Monthly Report
2018

CALLS FOR SERVICE SUMMARY

DEPARTMENT INFORMATION	JAN	FEB	MARCH	APRIL	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC	YTD
BINGO INSPECTIONS	05	04											09
FOOT PATROLS	20	23											43
HOUSING PATROLS	54	46											100
HANDICAP PERMITS	00	03											03
RESIDENCE CHECKS -Per residence	54	46											100
STREET LIGHTS OUT	03	07											10
BANK ESCORTS	08	00											08
CASES ASSIGNED													
NEW CASES	91	68											159
CLOSED CASES	88	66											154
OPEN CASES	03	02											05
CLOSED BY ARREST	05	08											12
CALLS FOR SERVICE	204	170											374
ARRESTS													
PENAL LAW ARRESTS	03	07											10
JUVENILE PETITIONS	00	00											00
UTTS/PARKING													
VEHICLE AND TRAFFIC TICKETS	17	02											19
PARKING TICKETS	02	13											15

ITEMS OF INTEREST:

Assist Citizen/Misc. Call For Service Category: Information requests, Attempt to Locate Person(s), Runaway, FOIL Requests, Health and Safety Concerns, Property (lost, found, retrieval), SOR address verifications and registrations, school threat, juvenile complaints (not petitions) and weather related complaints.

Arrest Charges: (1) Aggravated Unlicensed Operator 3rd, (4) Criminal Possession of a Controlled Substance, Failure to Register as a Sexual Offender, (3) Endangering the Welfare of a Child, (2) Harassment and (2) Possession of a Hypodermic Needle.

The department members completed the NYMIR Online University Training - Ethics.

Village Saint Johnsville WWTP

Monthly Report

Daily Responsibilities: Process control and record plant flow data. Clean off aerator rake and inspect influent pump system, clean off barscreen tray and check for issues. Collect and record aerator data and dissolved oxygen samples. Inspect basement for issue with sump pump. Collect and record sludge blanket thickness data. Run a settleometer test for sludge density and solids count. Microscope observations.

Weekly duties: Brush down Clarifier, effluent tanks and wier plates. Also clean off Parshell flume and sensor for flow monitor. Clean grit channel, run grit washer and dispose in dumpster. Dispose barscreen solids barrels and the aerator rakes buckets. Globes cleaned and filters kept clear of water and debris. Grease rake and check front of barscreen for grit and rocks, also tray and floors hosed off when necessary or weather permitted. Clarifier motor checked and chain oiled, platform cleaned of snow and ice.

Winter weather related duties: Keeping Aerator and digester platform free and clear of snow and ice. Sidewalks and steps by blower building and barscreen snow free. Keeping barscreen free of ice and just recently monitoring the screen more often because of sewer main plug ups bursting and collecting on screen. Plowing entrance road and plant lot. Use of backhoe move back snow piles and keeping back entrance clear to access village dump. Chopping holes in the ice to access decant pumps and freezing around power cords and lanyards. Also while pumping out water keeping ice layer from collapsing on pumps. Solids barrels and buckets from freezing. When wasting thaw out gates with torch without burning or scaring gate seals.

Other projects accomplished: Repaired cover on the influent flow pipe chase, heavy snow collapsed cover. Removed the old worn packings and replaced with new on the R.A.S. pump #2. Performed preventive maintenance on barscreen, influent pump system and clarifier. Repaired the water line for shower and bathroom sink. Snow blower to clear out from between clarifiers to have access to scum pit and pump scum to digester. Repair clarifier skimmer heavy snow bent the frame.